

GUIDE SPECIFICATION

Manufacturer:
CityScapes Inc.
4200 Lyman Court
Hilliard, Ohio 43026
(877) 727-3367 toll free
(800) 726-4817 facsimile
www.cityscapesinc.com

SECTION 32 35 00 [10821]

SITE SCREENING DEVICES

This guide specification has been prepared by CityScapes Inc. in printed and electronic media, as an aid to specifiers in preparing written construction documents for the Covrit custom fabricated site screens and gates for screening trash enclosures, mechanical units, and any other purposes where screening of vision is desirable.

Edit entire master to suit project requirements. Modify or add items as necessary. Delete items which are not applicable. Words and sentences within brackets [_____] reflect a choice to be made regarding inclusion or exclusion of a particular item or statement. This section may include performance, proprietary, and descriptive type specifications. Edit to avoid conflicting requirements. Editor notes to guide the specifier are included between lines of asterisks to assist in choices to be made. Remove these notes before final printing of specification.

This guide specification is written around the Construction Specifications Institute (CSI), Section Format standards references to section names and numbers are based on MasterFormat 2004. 5 digit numbers are listed in brackets in cast specifier prefers to use MasterFormat 1997.

For specification assistance on specific product applications, please contact our offices above.

Dimensions shown are hard imperial with soft metric conversions in parenthesis.

CityScrapes Inc. reserves the right to modify these guide specifications at any time. Updates to this guide specification will be posted to City Scapes' web site and/or in printed matter as they occur. Manufacturer and distributor make no expressed or implied warranties regarding content, errors, or omissions in the information presented.

PART 1 - GENERAL

1.01 SUMMARY

A. Section Includes:

1. Pre-formed thermoplastic panel for screening [trash enclosures], [mechanical units], [_____].
2. Aluminum support framing for direct attachment of screen support columns to paving, piers, or footings provided by others.
3. Operable gates for access through screens.

B. Products Not Installed or Furnished in This Section:

1. Touch-up painting required for scratches and screw heads.

2. Field painting of prime painted screens

Utilize the following reference if site screen system is to be bid as an alternate to a conventional masonry screen wall.

C. Related Sections:

1. Refer to Alternates, Section 01 23 00 [01230], for direction regarding bidding of screens as alternates.

1.02 REFERENCES

A. American Society for Testing and Materials: Standard Specifications for

1. ASTM B 221-96 - Aluminum and Aluminum Alloy Extruded Bars, Rods, Wire Profiles, and Tubes.

B. The Aluminum Association, Inc.

1. AA ADM-1516166 (1994) - Aluminum Design Manual

C. American Society of Civil Engineers.

1. ASCE 7-95 - Minimum Design Loads for Buildings and Other Structures.

1.03 SYSTEM DESCRIPTION

A. Design Criteria:

1. Manufacturer is responsible for the structural design of all materials, assembly and attachments to resist snow, wind, suction and uplift loading at any point without damage or permanent set.
2. Framing shall be designed in accordance with the Aluminum Design Manual to resist the following loading:
 - a. ASCE 7-95 - Minimum Design Loads for Buildings and Other Structures; American Society of Civil Engineers.

1.01 SUBMITTALS

A. Product Data: Submit manufacturer's catalog data, detail sheets, specification and other data sufficient to indicate compliance with these specifications.

B. Shop Drawings: Indicate layouts heights, component connection details, and details of interface with adjacent construction.

C. Samples:

1. Samples of Materials: Thermoplastic panels.
2. Color Selection: Submit paint chips with full range of colors available for Architect's selection.

D. Certification: Manufacturer's Certificate of Compliance certifying that thermoplastic panels supplied meet or exceed requirements specified.

E. Closeout Submittals: Warranty documents, issued and executed by manufacturer, countersigned by Contractor.

1.02 QUALITY ASSURANCE

A. Regulatory Requirements: Comply with requirements of building authorities having jurisdiction in Project location.

B. Manufacturer Qualifications: Minimum five (5) years documented experience producing systems specified in this section.

C. Pre-Installation Meeting:

1. Convene at job site seven (7) calendar days prior to scheduled beginning of construction activities of this section to review requirements of this section.
2. Require attendance by representatives of the installing subcontractor, (who will represent the system manufacturer) and other entities directly affected by construction activities of this section.
3. Notify Architect four (4) calendar days in advance of scheduled meeting date.

- 1.04 DELIVERY, STORAGE AND HANDLING
 - A. Delivery: Deliver materials to site in manufacturer's original, unopened containers and packaging, with labels clearly indicating manufacturer and material.
 - B. Storage and Handling: Protect materials and finishes during handling and installation to prevent damage.

- 1.04 PROJECT CONDITIONS
 - A. Field Measurements: Take measurements of supporting paving, footings, or piers. Indicate measurements on shop drawings fully documenting any field condition that may interfere with the screen system installation.

- 1.05 COORDINATION
 - A. Installer for work under this Section shall be responsible for coordination of panel and framing sizes and required options with the Contractor's requirements.
 - 1. Request information on sizes and options required from the Contractor.
 - B. Submit shop drawings to the Contractor and obtain written approval of shop drawing from the Contractor prior to fabrication.
 - C. Confirm size, type, and location of supporting construction as adequate to resist column supports.

- 1.6 WARRANTY
 - A. If any part of the screen system fails because of a manufacturing defect within one year from the date of substantial completion, the manufacturer will furnish without charge the required replacement part(s). Any local transportation, related service labor or diagnostic call charges are not included.

PART 2 - PRODUCTS

- 2.01 MANUFACTURERS
 - A. Acceptable Products: Covrit Gates and Screening System by CityScapes Incorporated, 4200 Lyman Ct. Hilliard, OH 43026. 1-877-727-3367 www.cityscapesinc.com
 - B. Substitutions: Submit in accordance with Section 01 25 00 [01600].

- 2.02 MATERIALS
 - A. Thermoformed Plastic Panels: Fabricated from rigid medium impact thermo-formed ABS (Acrylic Butylene Styrene) sheets.
 - 1. Minimum thickness: 3/16 inch (18 mm).
 - B. Framing: Aluminum Plate, Shapes and Bar: ASTM B 221, alloy 6061-T5 or 6063-T5.
 - C. Threaded Fasteners: All screws, bolts, nut and washers shall be Stainless steel.
 - 1. Corner assembly fasteners shall be #10-16 x stainless steel TEK screws.
 - 2. Provide lock washer or other locking device at all bolted connections.

- 2.03 FABRICATION
 - A. Provide factory-formed panel systems with continuous interlocking panel connections and indicated or necessary components: Form all components true to shape, accurate in size, square and free from distortion or defects. Cut panels to precise lengths indicated on approved shop drawings.
 - B. Fabricate products to the following configurations:

Make selections below from manufacturer's full available options. Panel styles and design can also be custom fabricated to customer's preferences. Note that gates and doors can also be fabricated from natural wood (cedar or redwood). Consult manufacturer for design options and finishes available.

Keep item 8 below if used for trash enclosure purposes. Series number reflects approximate size of layout.

- 1. Panel Style: [Lap Siding Over Brick] [Vertical Siding over Brick] [Lap Siding] [Vertical Siding] [Composite Tile] [Stucco Panels].
- 2. Panel Texture: [Decora] [Evolve].

- 3. Gate Style:
 - a. Park Collection: [Madison] [Monterey] [Radiant] [Laguna] [Muir Woods] [Augusta] [Redondo] [Sequoia].
 - b. Deco Collection: [Melrose] [Ruidoso] [Wendover] [Basalt] [Annapolis] [Atlantis] [Richland] [Santa Fe]
 - c. Innova Collection: [Canby] [Sonora] [Flagstaff] [Potomac] [Burlington] [Avon] [Bristol] [Kona].
- 4. Panel and Gate Height: [7] [8] feet.
- 5. Gate Width: [40] [63] [75] inches.
- 6. Decorative Top Rail Trim Profile: [Double Bevel] [Boxed] [Roman Ogee] [Coved].
- 7. Column Cap Style: [Hip] [Mortarboard] [Shadow Hip] [Shallow Hip].
- 8. Dumpster Layout: Series [1111] [1111-W] [1123] [1313] [1313-W] [1327].
- C. Trim and Closures: Fabricated from 24 gage metal, and finished with the manufacturers standard coating system, unless shown otherwise on drawings.
- D. Framing: Fabricate and assemble components in largest practical sizes, for delivery to the site.
 - 1. Construct corner assemblies to required shape with joints tightly fitted.
 - 2. Supply components required for anchorage of framing. Fabricate anchors and related components of material and finish as required, or as specifically noted.
- E. Gate Hardware: Provide manufacturer's standard adjustable cradle pipe hinge of size required to fit support pipe provided.

 Select either 2.04B 1 or 2 below depending on color selected. Contact manufacturer for minimum order for custom colors. Standard colors include 15 available options.

2.04 FINISHES

- A. Aluminum Framing: Mill finish.
- B. Panel Coating: Manufacturer's standard coating system, factory-applied.
 - 1. Color: Selected from full range of manufacturer's standard colors.
 - 2. [Color: Custom color as selected by Architect.]

PART 3 - EXECUTION

3.01 EXAMINATION

- A. Installer's Examination: Examine conditions under which construction activities of this section are to be performed.
 - 1. Submit written notification to Architect and Screen manufacturer if such conditions are unacceptable.
 - 2. Beginning erection constitutes installer's acceptance of conditions.

3.02 INSTALLATION

- A. Install units in accordance with the manufacturer's instructions and approved shop drawings. Keep perimeter lines straight, plumb, and level. Provide brackets, anchors, and accessories necessary for a complete installation.
- B. Fasten structural supports to paving, footings, or piers at spacings as indicated on approved shop drawings.
- C. Insert thermoplastic panels into structural supports, except where fixed attachment points are indicated. Butt thermoplastic panels to adjacent panels for uniform fit. Fasten fixed panels in accordance with the shop drawings.
- D. Metal Separation: Where aluminum materials would contact dissimilar materials, insert rubber grommets at attachment points, thus eliminating where dissimilar metals would otherwise be in contact.
- E. Do not cut or abrade finishes which cannot be restored. Return items with such finishes to shop for required alterations.

3.03 ERECTION TOLERANCES

- A. Maximum misalignment from true position: ¼ inch (12 mm).

3.04 CLEANING AND PROTECTION

- A. Remove all protective masking from material immediately after installation.

- B. Protection:

- 1. Ensure that finishes and structure of installed systems are not damaged by subsequent construction activities.
- 2. If minor damage to finishes occurs, repair damage in accordance with manufacturer's recommendations; provide replacement components if repaired finishes are unacceptable to Architect.

- C. Prior to Substantial Completion: Remove dust or other foreign matter from component surfaces; clean finishes in accordance with manufacturer's instructions.

- 1. Clean units in accordance with the manufacturer's instructions.

END OF SECTION